

PAVEMENT LEGEND

- ① 2.0" HOT MIX ASPHALT SUPERPAVE, 12.5MM FOR SURFACE, PG 64-22, LEVEL 3
- ② 3.0" HOT MIX ASPHALT SUPERPAVE, 19MM FOR BASE, PG 64-22, LEVEL 3
- ③ 4.0" GRADED AGGREGATE BASE COURSE



- ⑥ 4" PERVIOUS PORTLAND CEMENT CONCRETE
- ⑦ 20" WASHED AASHTO NO.2 AGGREGATE FOR STORMWATER MANAGEMENT FACILITIES
- ⑧ STANDARD MSHA TYPE A CONCRETE CURB AND GUTTER (MSHA STD. NO. MD 620.02)
- ⑨ LONGITUDINAL UNDERDRAIN (MSHA STANDARD 387.11). LONGITUDINAL UNDERDRAIN SHALL BE WRAPPED IN CLASS SD TYPE II GEOTEXTILE.
- ⑩ TOP OF SUBGRADE AND LIMIT OF CLASS I EXCAVATION
- ⑪ TOP OF EXISTING PAVEMENT AFTER 2" MILLING
- ⑫ EXISTING SUBGRADE
- ⑬ 2" NO. 57 AGGREGATE FOR STORMWATER MANAGEMENT FACILITIES
- ⑭ VARIABLE DEPTH WEDGE/LEVEL USING HMA (SEE NOTES 4 & 5)

NOTES:


1. ALL SIDEWALK RAMPS SHALL BE STANDARD CONCRETE (IMPERVIOUS) SIDEWALK SEE MC. STD. 111.01 FOR GENERAL NOTES AND DETAILS.
2. SEE "SECTION 610 – PAVEMENT SIDEWALKS AND BIKEPATHS" TO COMPLY WITH MCDOT CONSTRUCTION AND INSTALLATION SPECIFICATIONS.
3. PERVIOUS CONCRETE – ALL CONSTRUCTION MUST BE DONE PER THE LATEST SECTION OF ACI 522.1-08.

4. USE THE FOLLOWING ITEM FOR WEDGE/LEVEL, AS DIRECTED BY ENGINEER:


IN CASES WHERE UP TO 2" OF WEDGE/LEVELING IS REQUIRED, USE THE FOLLOWING MATERIAL: VARIABLE DEPTH HOT MIX ASPHALT SUPERPAVE 9.5MM FOR WEDGE/LEVEL; PG 64-22, LEVEL 3 (1" MINIMUM, 2" MAXIMUM LIFTS)

IN CASES WHERE THE TOTAL REQUIRED WEDGE/LEVEL THICKNESS IS GREATER THAN 2", USE THE FOLLOWING MATERIAL: VARIABLE DEPTH HOT MIX ASPHALT SUPERPAVE 19.0MM FOR WEDGE/LEVEL; PG 64-22, LEVEL 3 (2" MINIMUM, 4" MAXIMUM LIFTS)


5. FOR AREAS WHERE THE GRADE IS INCREASED FROM 2 INCHES TO 11 INCHES PLACE A VARIABLE DEPTH OF WEDGE/LEVEL HMA TO THE BOTTOM OF THE FINAL SURFACE LAYER



(A) TYPICAL PAVEMENT DETAIL
SCALE: N.T.S.



(B) MILLING AND RESURFACE DETAIL
SCALE: N.T.S.



SHARED USE PATH SECTION

STA. 163+55.37 TO STA. 171+72.20, LT


SCALE: N.T.S.

NOTE:


5' WIDE CONCRETE SIDEWALK

STA. 164+50.0 TO STA. 173+02.0, RT

SEE STD MC-111.01



© HMA WEDGE LEVEL SECTION
SCALE: N.T.S.

 ADDENDUM NO. 3		1/5/2018	GF	MONTGOMERY COUNTY DEPARTMENT OF TRANSPORTATION ROCKVILLE, MARYLAND		<h1 style="text-align: center;">SNOUFFER SCHOOL ROAD</h1>	
				RECOMMENDED FOR APPROVAL			
				Chief, Design Section _____ Date _____ APPROVED			
				Chief, Division of Transportation Engineering _____ Date _____			
				Designed by: <u>GW</u> Drawn by: <u>GW</u> Checked by: <u>BDP</u>		SCALE : 1" = 10'	
NO.	REVISION	DATE	BY			Project No. : 2000661 (501119) _____ 6 of 157	